

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Zhejiang Ruihua Machinery Co., Ltd	Client ID	102557
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.3-2007 : Portable fire extinguishers - Specific requirements for wet chemical type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	10/09/2019	Certification Expiry Date	10/09/2024
Certificate Issue Date	9/05/2015	Certificate Last Update Date	6/05/2024

APPROVED COMPANY / SITE ADDRESS(ES):

Western Industrial Zone, Lingshan Town Yuyao Zhejiang 315460 China

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager


Unique Certificate Code: EBFCD7999A26DFC4CA258AF00005F8D6

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®

JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
WC20	2.0 L Wet Chem type extinguisher	Presto	2.0 L wet chem type, Rating: 2A:4F, FERN: 2557.03-100	25-Feb-15
WC20	2.0 L Wet Chem type extinguisher	FireWorld	2.0 L wet chem type, Rating: 2A:4F, FERN: 2557.03-200	25-Feb-15
WC20	2.0 L Wet Chem type extinguisher	No name	2.0 L wet chem type, Rating: 2A:4F, FERN: 2557.03-300	25-Feb-15
WC70	7.0 L Wet Chem type extinguisher	Presto	7.0 L wet chem type, Rating: 3A:4F, FERN: 2557.03-101	25-Feb-15
WC70	7.0 L Wet Chem type extinguisher	FireWorld	7.0 L wet chem type, Rating: 3A:4F, FERN: 2557.03-201	25-Feb-15
WC70	7.0 L Wet Chem type extinguisher	No name	7.0 L wet chem type, Rating: 3A:4F, FERN: 2557.03-301	25-Feb-15
FAT20	2.0 L Wet Chem type extinguisher	Presto	2.0 L wet chem (fluorine free) type, Rating: 1A:4F, FERN: 2557.03-102	25/03/2024
FAT20	2.0 L Wet Chem type extinguisher	FireWorld	2.0 L wet chem (fluorine free) type, Rating: 1A:4F, FERN: 2557.03-202	25/03/2024
FAT20	2.0 L Wet Chem type extinguisher	No name	2.0 L wet chem (fluorine free) type, Rating: 1A:4F, FERN: 2557.03-302	25/03/2024
FAT70	7.0 L Wet Chem type extinguisher	Presto	7.0 L wet chem type (fluorine free), Rating: 3A:4F, FERN: 2557.03-103	25/03/2024
FAT70	7.0 L Wet Chem type extinguisher	FireWorld	7.0 L wet chem type (fluorine free), Rating: 3A:4F, FERN: 2557.03-203	25/03/2024
FAT70	7.0 L Wet Chem type extinguisher	No name	7.0 L wet chem (fluorine free) type, Rating: 3A:4F, FERN: 2557.03-303	25/03/2024

Comments:

Extinguisher construction complies with AS/NZS 1841.1 standard requirements.

End of the document



Certification Manager

